

Seattle Fire Department Permit Application
Code 2521 Tire and Tire Byproduct Storage

Level I
--Revised 1/2005--



Permit Fee: \$152.00

TO BE COMPLETED BY PERMIT APPLICANT (PLEASE PRINT)

FIRM NAME		
MAILING ADDRESS	SUITE	
CITY	STATE	ZIP
OPERATION ADDRESS		
CONTACT PERSON	PHONE NUMBER ()	
Please include a check made payable to the CITY OF SEATTLE with this application.		

Permit applications may be submitted in person weekdays from 8:00 a.m. to 4:30 p.m., or mailed to:

Seattle Fire Department
Fire Marshal's Office—Permits
220 Third Avenue South, Second Floor
Seattle, WA 98104-2608

Permit processing: (206) 386-1025
www.seattle.gov/fire

TO BE COMPLETED BY INSPECTING ENGINE/LADDER COMPANY:

TYPE OF MATERIAL	AMOUNT	LOCATION
Example: Tires	3,000 cubic feet	NE corner of main warehouse
<input type="checkbox"/> Permit Conditions Approved		
Inspected By:	C/P/O:	SFD ID#:
Station No.	Occ. No.:	Date:
Special Permit Conditions: (continue on back if necessary)		

FMO OFFICE USE ONLY:

Date Received:	Receipt No.:	Check No.:
Expiration Date with Existing Permits:		Application ID#
<input type="checkbox"/> Cancel with full refund <input type="checkbox"/> Cancel, no refund <input type="checkbox"/> Moved <input type="checkbox"/> No Longer Needs <input type="checkbox"/> Out of Business		

PERMIT CONDITIONS:**INDOOR STORAGE:**

1. Storage shall be maintained 2 feet or more below the ceiling in non-sprinklered areas of buildings. Storage shall be maintained 18 inches or more below sprinkler head deflectors in sprinklered areas of buildings. (2003 SFC 315.2.1)
2. The top of the storage shall not exceed 6 feet in height. (2003 SFC 2302.1)
3. Storage shall be within 20 feet of two aisles each at least 44 inches wide. (2003 SFC 315.2.5)
4. No block pile shall exceed 40 x 40 feet. (2003 SFC 315.2.5)
5. No dead end aisle shall be longer than 10 times its width. (2003 SFC 315.2.5)
6. All storage in unsprinklered areas shall be within 150 feet aisle travel of an exterior door. (2003 SFC 315.2.5)
7. Storage shall not obstruct access to extinguishers, standpipe outlets, sprinkler control shut down and safety controls or fire department access openings. (2003 SFC 315.2.5)

OUTDOOR STORAGE:

8. Tire storage shall be located at least 50 feet from lot lines and buildings.
Exception: Tires stored on a single rack having dimensions not exceeding 68" x 48"x 76" for commercial display, the distance to property lines that can be built upon may be reduced to 10 ft and no separation is required from buildings on the same property. (2003 SFC 2505.4)
9. Tire storage piles shall not be located beneath electrical power lines having a voltage in excess of 750 volts or that supply power to fire emergency systems. (2003 SFC 2504.4)
10. Tire piles shall not exceed 5,000 square feet of continuous area. (2003 SFC 2505.1)
11. Tire piles shall not exceed 50,000 cubic feet in volume or 10 feet in height. (2003 SFC 2505.1)
12. Individual tire piles shall be separated from other piles of salvage and from piles of other stored material by a clear space of at least 40 feet. (2003 SFC 2505.2)
13. Weeds, grass, vines and other growth that is capable of being ignited and endangering property shall be removed by the owner or occupant (2003 SFC 304.1.2)